

City of Las Vegas Code and Interpretation

AMEND: 18

DATE: December 19, 2008

CODE: 2006 IBC ☒ 2005 NEC ☐ Local Amendments ☐
 2006 IRC ☐ 2006 UMC ☐ POOL CODE ☐
 2006 IECC ☐ 2006 UPC ☐ MISC. ☐ Admin Code

CODE SECTION: R 105.2

TOPIC: Storage Sheds and other accessory structures and location on property.

PURPOSE/REASON: What is City policy regarding a one-story accessory structures for set backs and fire rating. Code states permit not required and sets back is 3 feet per the CLV municipal code.

INTERPRETATION: Since Chapter 1 of the 2006 IRC has been deleted in its entirety – refer to CLV Amendments. Since a permit is required per the CLV Amendments, comply with section R 302 for separation distance and fire rating.

Approved: Chris Knight, CBO